



Office of the Mayor-President
Purchasing Division

City of Baton Rouge
Parish of East Baton Rouge
222 St. Louis St. 8th Floor Room 826
P.O.Box 1471

225/389-3259 FAX 225/389-4841
purchasinginfo@brgov.com

Kris Goranson
Director of Purchasing

ADDENDUM NO. 1
December 22, 2021

Your reference is directed to: **File Number: 21-00300**

Solicitation: **A21-0300 Aggregates and Soils**

which is scheduled to open: **January 5, 2022**

Question 1: I am looking for specifications (ie Gradations) for the stone types listed in this RFQ Items 19 – 41. Especially Item 039- 041 Man Size Rip Rap. Does the City of Baton Rouge, East Baton Rouge Parish, have standard description or specification for Man Size Rip Rap? Please Advise.

Answer 1: Class 2 Rip-Rap –No more than 10% of the stone will have a diameter greater than sixteen (16) inches; no more than 50% of the stone will have a diameter less than twelve (12) inches; and no more than 10% of the stone will have a diameter of less than six (6) inches. The thickness of the rip-rap liner will be no less than sixteen (16) inches.

This addendum is hereby officially made a part of the referenced solicitation and should be attached to the bidder's proposal or otherwise acknowledged therein. If you have already submitted your proposal and this addendum causes you to revise your original bid, please indicate changes herein and return to Purchasing prior to bid opening in an envelope marked with the file number, bid opening date, and time. If this addendum does not cause you to revise your bid, please acknowledge receipt of the addendum by signing your name and company below and returning it in accordance with the provisions above.

cc: Bid File 21-00300

ssylvan@brla.gov
225-389-3259 x 3263

Signature

Date

Company